



*Effective and Economical  
Environmental Solutions*

**Lead in Drinking Water Sampling  
Per amendments to N.J.A.C 6A:26 Educational Facilities  
The Eden School  
2 Merwick Road  
Princeton, NJ 08540  
Karl Environmental Group Project #: 25-0587**

**April 17, 2025**

Prepared for:  
John Gennuso  
Facility Manager  
The Eden School  
2 Merwick Road  
Princeton, NJ 08540

Prepared by:  
Karl Environmental Group  
20 Lauck Road  
Mohnton, PA 19540  
Tel: (800) 527-5581  
Fax: (610) 856-5040



20 Lauck Road  
Mohnton, PA 19540  
Tel: (800) 527-5581  
Fax: (610) 856-5040  
Web: [www.karlenv.com](http://www.karlenv.com)

April 17, 2025

John Gennuso  
Facility Manager  
The Eden School  
2 Merwick Road  
Princeton, NJ 08540

**Re: Lead in Drinking Water Sampling  
Per amendments to N.J.A.C 6A:26 Educational Facilities  
The Eden School  
Karl Environmental Group Project #: 25-0587**

Dear Mr. Gennuso:

Thank you for selecting Karl Environmental Group (“Karl”) for this project. This report details the methods and findings of the lead in drinking water services as per New Jersey state regulations (amendments to N.J.A.C 6A:26 Educational Facilities) performed within The Eden School (the “Facility”), on April 9, 2025.

## **1.0 PROJECT BACKGROUND**

Karl Environmental was contacted by Eden Autism Services (the “Client”) to perform lead in drinking water sampling to determine the lead content of drinking water from sources throughout the Facility.

The purpose of lead in drinking water sampling is to determine if any sampled drinking water sources exhibit lead levels exceeding the Regulatory Action Level of 15 parts per billion (ppb). Drinking water collection points included any water sources from which a student, staff, or faculty may reasonably drink or from which the water may be used for cooking or beverage preparation, including, but not limited to, water coolers/bubblers, kitchen faucets, Nurse’s Office faucets, and Faculty/Staff lounges.



## 2.0 LEAD IN DRINKING WATER

Lead is a toxic substance that can be harmful to human health. As compared to adults, children are more susceptible to the detrimental health effects of lead, as their nervous systems are not yet fully developed. Exposure to lead can occur in a variety of ways including through food, soil, deteriorating lead-based paint, and drinking water. Lead can leach into drinking water from plumbing materials such as pipes and solder, as well as brass plumbing fixtures. For this investigation, planning, preparation, methodology, sampling, and follow-up actions were conducted according to the technical guidance provided by New Jersey following the adoption of amendments to N.J.A.C. 6A:26: Educational Facilities, requiring the sampling of drinking water for lead in schools.

## 3.0 DRINKING WATER SAMPLING METHODOLOGY

Karl collected nineteen (19) drinking water samples from water outlets throughout the Facility and one (1) field blank sample. At each collection point, Karl Environmental filled a 250 milliliter (mL) wide-mouth high density polyethylene (HDPE) sample collection bottle from the selected water source. Samples were collected after the water in each building had not been used for at least 8 hours, but not more than 48 hours. The initial sample at each collection point represents the first draw sample. The first draw sample is representative of the water from the end point of the water source (i.e., the bubbler or tap).

A field blank using lead-free laboratory reagent water was also collected at each Facility during the sampling event to rule out contamination of samples during the collection and transportation process. All samples were recorded under proper chain of custody and couriered to Suburban Testing Labs (Suburban), a New Jersey certified laboratory (NJ Lab ID #PA081) located in Reading, Pennsylvania for analysis by EPA method 200.8, NJ DOE.

During the initial sampling event, Karl Environmental Group collected the following number of samples at each Facility:

### The Eden School

- Nineteen (19) First Draw Samples
- One (1) Field Blank



#### 4.0 DRINKING WATER ANALYSIS RESULTS

The analytical lead in drinking water results are listed in the table below:

**Table 1: The Eden School – April 9, 2025**

Sample I.D.	Type of Collection Point	Lead Concentration (ppb)	Above Regulatory Action Level?
EA-BLANK	Blank	< 1.00	No
EA-FP-1FL-KITCH-3	Food Prep Sink	2.70	No
EA-FP-1FL-KITCH-2	Food Prep Sink	<1.00	No
EA-FP-1FL-KITCH-1	Food Prep Sink	9.60	No
EA-FP-1FL-CAFÉ	Food Prep Sink	< 1.00	No
EA-WC-1FL-HALLEXER	Water Cooler	<1.00	No
EA-TL-2FL-STAFF	Teacher's Lounge Sink	< 1.00	No
EA-CF-2FL-STAFF	Coffee Filler	< 1.00	No
EA-WC-2FL-STAFF	Water Cooler	< 1.00	No
EA-WC-2FL-HALL209-2	Water Cooler	< 1.00	No
EA-WC-2FL-HALL209-1	Water Cooler	< 1.00	No
EA-CF-1FL-STORE	Coffe Filler	< 1.00	No
EA-WC-1FL-HALLREC-1	Bottle Filler	<1.00	No
EA-WC-1FL-HALLREC-2	Water Cooler	<1.00	No
EA-NS-1FL-NURSE	Nurse's Sink	< 1.00	No
EA-FP-1FL-146	Food Prep Sink	< 1.00	No
EA-FP-1FL-143	Food Prep Sink	< 1.00	No
EA-FP-1FL-149	Food Prep Sink	< 1.00	No
EA-FP-2FL-241	Food Prep Sink	< 1.00	No
EA-FP-2FL-251	Food Prep Sink	< 1.00	No
EA-DW-2FL-HALL246-2	Bottle Filler	<1.00	No
EA-DW-2FL-HALL246-1	Water Cooler	<1.00	No

All laboratory analytical results were compared to the Regulatory Action Level of 15 ppb for lead. Analysis of lead in the first draw drinking water samples indicated that at the time of the sampling event, none of the results were above the action level of 15 ppb for lead.



## 5.0 CONCLUSIONS & RECOMMENDATIONS

Following the lead in drinking water sampling event conducted on April 9, 2025, none of the outlets were above the Regulatory Action Level of 15 ppb. At the conclusion of the lead in drinking water services, Karl Environmental offers the following recommendations at this time:

- Continue to monitor lead in drinking water levels as part of a regular sampling and maintenance plan, as per New Jersey State regulations. Amendments will require district-wide sampling every three (3) years.
- In the interim, when drinking water outlets are replaced/added, or the plumbing is disturbed, sampling of the impacted outlets should be completed to determine if lead levels were affected.
- Implement an aerator cleaning maintenance program to prevent the build-up of debris behind the screen which may contribute to elevated lead levels.
- Enter all filter maintenance, aerator maintenance, plumbing repairs/changes and any other pertinent information into the Field Log Book for each Facility.
- Use only cold water for food and beverage preparation. Hot water is more likely to contribute to the corrosion of plumbing materials and therefore contain a greater level of contaminants from the plumbing system.

## 6.0 LIMITATIONS

This investigation focused on lead in drinking water only. No other heavy metals or additional contaminants were sampled for or analyzed. Lead concentrations can change as water continues to move through the water system. Each sample was a grab sample and represents lead concentrations only at the specific time of collection and may vary based on the water usage in the facility. Interpretation of these results is only valid if the facility is serviced by a municipal water supplier or water utility.

This lead sampling event was in response to the amendments to N.J.A.C. 6A:26, Educational Facilities dated July 13, 2016, which requires testing for lead in the drinking water of public and charter school districts every three (3) years.



## 7.0 CLOSING

Thank you for using Karl Environmental Group to assist you with this project. Please do not hesitate to call if you have any questions relating to this report or for any other environmental health and safety concerns.

Respectfully submitted,  
**Karl Environmental Group**

*Angela Meas*

Angela Meas  
Industrial Hygienist  
Karl Environmental Group  
Office: (610)-856-7700  
Fax: (610)-856-5040  
Cell: 484-345-9846  
Email: [ameas@karlenv.com](mailto:ameas@karlenv.com)



# **Attachment A:**

# **Analytical Lab Results**



Built Environment Testing

iATL

9000 Commerce Parkway Suite B  
Mt. Laurel, New Jersey 08054  
Telephone: 856-231-9449  
Email: customerservice@iatl.com

CERTIFICATE OF ANALYSIS

Client: Karl Environmental Group  
20 Lauck Road  
Mohnton PA 19540

Report Date: 4/14/2025  
Report No.: 711891 - Lead Water  
Project: Eden Autism  
Project No.: 25-0587

Client: KAR387

LEAD WATER SAMPLE ANALYSIS SUMMARY

Lab No.: 7834660                      Location: Blank                      Result(ppb): <1.00  
Client No.: EA-Blank                      \* Sample acidified to pH <2.

Lab No.: 7834661                      Location: Sink Mid                      Result(ppb): 2.70  
Client No.: EA-FP-1FL-KITCH-3                      \* Sample acidified to pH <2.

Lab No.: 7834662                      Location: Sink R                      Result(ppb): <1.00  
Client No.: EA-FP-1FL-KITCH-2                      \* Sample acidified to pH <2.

Lab No.: 7834663                      Location: Sink By Desk                      Result(ppb): 9.60  
Client No.: EA-FP-1FL-KITCH-1                      \* Sample acidified to pH <2.

Lab No.: 7834664                      Location: Sink                      Result(ppb): <1.00  
Client No.: EA-FP-1FL-Cafe                      \* Sample acidified to pH <2.

Lab No.: 7834665                      Location: WC                      Result(ppb): <1.00  
Client No.: EA-WC-1FL-HallExer                      \* Sample acidified to pH <2.

Lab No.: 7834666                      Location: WC                      Result(ppb): <1.00  
Client No.: EA-WC-2FL-Staff                      \* Sample acidified to pH <2.

Lab No.: 7834667                      Location: Coffee Filler                      Result(ppb): <1.00  
Client No.: EA-CF-2FL-Staff                      \* Sample acidified to pH <2.

Lab No.: 7834668                      Location: Sink                      Result(ppb): <1.00  
Client No.: EA-TL-2FL-Staff                      \* Sample acidified to pH <2.

Lab No.: 7834669                      Location: WC Left                      Result(ppb): <1.00  
Client No.: EA-WC-2FL-Hall209-2                      \* Sample acidified to pH <2.

Please refer to the Appendix of this report for further information regarding your analysis.

Date Received: 4/9/2025  
Date Analyzed: 04/14/2025  
Signature:   
Analyst: Chad Shaffer

Approved By:   
Frank E. Ehrenfeld, III  
Laboratory Director





Built Environment Testing

iATL

9000 Commerce Parkway Suite B  
Mt. Laurel, New Jersey 08054  
Telephone: 856-231-9449  
Email: customerservice@iatl.com

CERTIFICATE OF ANALYSIS

Client: Karl Environmental Group  
20 Lauck Road  
Mohnton PA 19540

Report Date: 4/14/2025  
Report No.: 711891 - Lead Water  
Project: Eden Autism  
Project No.: 25-0587

Client: KAR387

LEAD WATER SAMPLE ANALYSIS SUMMARY

Lab No.: 7834670                      Location: WC Right                      Result(ppb): <1.00  
Client No.: EA-WC-2FL-Hall209-1      \* Sample acidified to pH <2.

Lab No.: 7834671                      Location: Sink                      Result(ppb): <1.00  
Client No.: EA-CF-1FL-Store              \* Sample acidified to pH <2.

Lab No.: 7834672                      Location: WC Left                      Result(ppb): <1.00  
Client No.: EA-WC-1FL-HallRec-1        \* Sample acidified to pH <2.

Lab No.: 7834673                      Location: WC Right                      Result(ppb): <1.00  
Client No.: EA-WC-1FL-HallRec-2        \* Sample acidified to pH <2.

Lab No.: 7834674                      Location: Sink Back                      Result(ppb): <1.00  
Client No.: EA-NS-1FL-Nurse              \* Sample acidified to pH <2.

Lab No.: 7834675                      Location: Sink                      Result(ppb): <1.00  
Client No.: EA-FP-1FL-143                \* Sample acidified to pH <2.

Lab No.: 7834676                      Location: Sink                      Result(ppb): <1.00  
Client No.: EA-FP-1FL-146                \* Sample acidified to pH <2.

Lab No.: 7834677                      Location: Sink                      Result(ppb): <1.00  
Client No.: EA-FP-1FL-149                \* Sample acidified to pH <2.

Lab No.: 7834678                      Location: Sink                      Result(ppb): <1.00  
Client No.: EA-FP-2FL-241                \* Sample acidified to pH <2.

Lab No.: 7834679                      Location: Sink                      Result(ppb): <1.00  
Client No.: EA-FP-2FL-251                \* Sample acidified to pH <2.

Please refer to the Appendix of this report for further information regarding your analysis.

Date Received: 4/9/2025  
Date Analyzed: 04/14/2025  
Signature:   
Analyst: Chad Shaffer

Approved By:   
Frank E. Ehrenfeld, III  
Laboratory Director

---

CERTIFICATE OF ANALYSIS

---

Client: Karl Environmental Group  
20 Lauck Road  
Mohnton PA 19540

Report Date: 4/14/2025  
Report No.: 711891 - Lead Water  
Project: Eden Autism  
Project No.: 25-0587

Client: KAR387

## Appendix to Analytical Report:

**Customer Contact:** Mike Karl  
**Analysis:** AAS-GF - ASTM D3559-15D

This appendix seeks to promote greater understanding of any observations, exceptions, special instructions, or circumstances that the laboratory needs to communicate to the client concerning the above samples. The information below is used to help promote your ability to make the most informed decisions for you and your customers. Please note the following points of contact for any questions you may have.

**iATL Customer Service:** customerservice@iatl.com  
**iATL Office Manager:** ?wchampion@iatl.com  
**iATL Account Representative:** Shirley Clark  
**Sample Login Notes:** See Batch Sheet Attached  
**Sample Matrix:** Water  
**Exceptions Noted:** See Following Pages

### General Terms, Warrants, Limits, Qualifiers:

General information about iATL capabilities and client/laboratory relationships and responsibilities are spelled out in iATL policies that are listed at [www.iATL.com](http://www.iATL.com) and in our Quality Assurance Manual per ISO 17025 standard requirements. The information therein is a representation of iATL definitions and policies for turnaround times, sample submittal, collection media, blank definitions, quantification issues and limit of detection, analytical methods and procedures, sub-contracting policies, results reporting options, fees, terms, and discounts, confidentiality, sample archival and disposal, and data interpretation.

iATL warrants the test results to be of a precision normal for the type and methodology employed for each sample submitted. iATL disclaims any other warrants, expressed or implied, including warranty of fitness for a particular purpose and warranty of merchantability. iATL accepts no legal responsibility for the purpose for which the client uses test results. Any analytical work performed must be governed by our Standard Terms and Conditions. Prices, methods and detection limits may be changed without notification. Please contact your Customer Service Representative for the most current information.

This confidential report relates only to those item(s) tested and does not represent an endorsement by NIST-NVLAP, AIHA LAP LLC, or any agency of local, state or province governments nor of any agency of the U.S. government.

This report shall not be reproduced except in full, without written approval of the laboratory.

### Information Pertinent to this Report:

Analysis by AAS Graphite Furnace:

- ASTM D3559-15D

Certification:

- NYS-DOH No. 11021

- NJDEP No. 03863

### Note: These methods are analytically equivalent to iATL's accredited method;

- USEPA 40CFR 141.11B

- USEPA 200.9 Pb, AAS-GF, RL <2 ppb/sample

- USEPA SW 846-7421 - Pb(AAS-GF, RL <2 ppb/sample)

Regulatory limit for lead in drinking water is 15.0 parts per billion as cited in EPA 40 CFR 141.11 National Primary Drinking Water Regulations, Subpart B: Maximum contaminant levels for inorganic chemicals.

All results are based on the samples as received at the lab. iATL assumes that appropriate sampling methods have been used and that the data upon which these results are based have been accurately supplied by the client.

Sample results are not corrected for contamination by field or analytical blanks.

PPB = Parts per billion. 1 µg/L = 1 ppb MDL = 0.24 PPB Reporting Limit (RL) = 1.0 PPB

---

CERTIFICATE OF ANALYSIS

---

Client: Karl Environmental Group  
20 Lauck Road  
Mohnton PA 19540

Report Date: 4/14/2025  
Report No.: 711891 - Lead Water  
Project: Eden Autism  
Project No.: 25-0587

Client: KAR387

**Disclaimers / Qualifiers:**

There may be some samples in this project that have a "NOTE:" associated with a sample result. We use added disclaimers or qualifiers to inform the client about something that requires further explanation. Here is a complete list with highlighted disclaimers pertinent to this project. For a full explanation of these and other disclaimers, please inquire at [customerservice@iatl.com](mailto:customerservice@iatl.com).

Matrix spiking is performed on each client batch to determine if interferences could impact results. When spike recoveries fall out of acceptable range matrix interference is suspected and samples are diluted until acceptable spike recovery can be achieved. Reporting limits will increase by the same degree as the dilution required.

Note: Sample dilution required due to matrix interference.

Water Sample Turbidity greater than 1.0 NTU does not meet Federal and NJ State Primary & Secondary Drinking Water Standards.

\* ASTM D3559 (D) calls for the addition of acid at the time of sampling. Unless so noted on the chain of custody by the client iATL acidifies samples to a pH of <2 at least 24 hours prior to analysis.

20



## Chain of Custody

- Environmental Lead -

### Contact Information

Client Company:	<u>Karl Environmental Group</u>	Project Number:	<u>25-00587</u>
Office Address:	<u>20 Lack Road</u>	Project Name:	<u>Eden Autism</u>
City, State, Zip:	<u>Mohnton, PA</u>	Primary Contact:	<u>Barry M. Hunsberger</u>
Fax Number:	<u>610-856-5040</u>	Office Phone:	<u>800-527-5581</u>
Email Address:	<u>bhunsberger@karlenv.com</u>	Cell Phone:	<u>1-484-269-7870</u>

iATL is accredited by the National Lead Laboratory Accreditation Program (NLLAP) to perform analytical testing of environmental samples for lead (Pb). The accreditation is through AIHA-LAP, LLC and several other nationally recognized state programs.

### Matrix/Method:

- Paint by AAS: ASTM D3335-85a, 2009
- Wipe/Dust by AAS: SW 846; 3050B; 700B, 2010
- Air by AAS: NIOSH 7082, 1994
- Soil by AAS: EPA SW 846 (Soil)
- Water by AAS-GF: ASTM D3559-03D, US EPA 200.9
- Other Metals (Cd, Zn, Cr) by AAS
- Toxicity Characteristic Leaching Procedure (TCLP) by AAS: US EPA 1311
- Other \_\_\_\_\_

### Special Instructions:

200.8

### Turnaround Time

Preliminary Results Requested Date: \_\_\_\_\_  Verbal  Email  Fax

10 Day  5 Day  3 Day  2 Day  1 Day\*  12 Hour\*\*  6 Hour\*\*  RUSH\*\*

\* End of next business day unless otherwise specified. \*\* Matrix Dependent. \*\*\*Please notify the lab before shipping\*\*\*

RECEIVED

### Chain of Custody

Relinquished (Name/Organization):	<u>Karl environmental</u>	Date:	<u>4/9/2025</u>	Time:	
Received (Name / iATL):		Date:		Time:	<u>APR -- 5 2025</u>
Sample Login (Name / iATL):		Date:		Time:	
Analysis(Name(s) / iATL):		Date:		Time:	
QA/QC Review (Name / iATL):		Date:		Time:	
Archived / Released:		QA/QC InterLAB Use:		Date:	



## Sample Log

—Environmental Lead—

Client: Karl Environmental Project: 25-0587-Eden Astoria

Sampling Date/Time: 4/9/2025

Client Sample #	iATL #	Location/ Description	Flow Rate	Start End	Sampling time (min)	Area (ft2) Volume (L)	Results ( )
EA-Blank	7834660	Blank				250 ml	
EA-FP-1FL-KITCH-3	7834661	Sink-mid				250 ml	
EA-FP-1FL-KITCH-2	7834662	Sink-R				250 ml	
EA-FP-1FL-KITCH-1	7834663	Sink-by desk				250 ml	
EA-FP-1FL-Cafe	7834664	Sink				250 ml	
EA-WC-1FL-HALL EXER	7834665	WC				250 ml	
EA-WC-2FL-Staff	7834666	WC				250 ml	
EA-CF-2FL-Staff	7834667	Coffee Filter				250 ml	
EA-TL-2FL-Staff	7834668	Sink				250 ml	
EA-WC-2FL-Hall 209-2	7834669	WC Left				250 ml	
EA-WC-2FL-Hall 209-1	7834670	WC Right				250 ml	
EA-CF-1FL-STORE	7834671	Sink				250 ml	
EA-WC-1FL-Hall REC-1	7834672	WC-Left				250 ml	
EA-WC-1FL-Hall REC-2	7834673	WC-Right				250 ml	
EA-NS-1FL-INV RCE	7834674	Sink Back				250 ml	

\* = Insufficient Sample Provided to Perform QC Reanalysis (<200mg)

\*\* = Insufficient Sample Provided to Analyze (<50mg) \*\*\* = Matrix / Substrate Interference Possible

FB = Method Requires the submittal of blank(s). ML = Multi Layered Sample. May result in inconsistent results.

These preliminary results are issued by iATL to expedite procedures by clients based upon the above data. iATL assumes that all of the sampling methods and data upon which these results are based, has been accurately supplied by the client. These results may not have been reviewed by the Laboratory Director. Final Certificate of Analysis will follow these preliminary results. The signed COA is to be considered the official results. All EPA, HUD, and NJDEP conditions apply.

## Sample Log

-Environmental Lead -

Client: Karl Environmental Project: 25-0587 - Eden Autism

Sampling Date/Time: 4/9/25

Client Sample #	IATL #	Location/Description	Flow Rate	Start End	Sampling time (min)	Area (ft <sup>2</sup> ) Volume (L)	Results ( )
EA-FP-1FL-143	7834675	Sink				250ml	
EA-FP-1FL-146	7834676	Sink				250ml	
EA-FP-1FL-149	7834677	Sink				250ml	
EA-FP-2FL-241	7834678	Sink				250ml	
<del>EA-<del>FP-2FL-241</del></del>						<del>250ml</del>	
EA-EA-FP-2FL-251	7834679	Sink				250ml	
<del>EA-FP-2FL-251</del>		<del>Sink</del>				<del>250ml</del>	
<del>EA-FP-2FL-251</del>		<del>Sink</del>				<del>250ml</del>	

\* = Insufficient Sample Provided to Perform QC Reanalysis (<200mg)  
 \*\* = Insufficient Sample Provided to Analyze (<30mg) \*\*\* = Matrix / Substrate Interference Possible  
 FB = Method Requires the submittal of blank(s). ML = Multi Layered Sample. May result in inconsistent results.  
 These preliminary results are issued by IATL to expedite procedures by clients based upon the above data. IATL assumes that all of the sampling methods and data upon which these results are based, has been accurately supplied by the client. These results may not have been reviewed by the Laboratory Director. Final Certificate of Analysis will follow these preliminary results. The signed COA is to be considered the official results. All EPA, HUD, and NJDEP conditions apply.