Tuesday, August 29, 2017

Eden Autism Services The Eden School 2 Merwick Road, Princeton NJ 08540

Dear Eden School Community,

Our school system is committed to protecting student, teacher, and staff health. To protect our community and be in compliance with the Department of Education regulations, the District of Princeton tested our schools' drinking water for lead.

In accordance with the Department of Education regulations, the Eden School will implement immediate remedial measures for any drinking water outlet with a result greater than the action level of 15 μ g/l (parts per billion [ppb]). This includes turning off the outlet unless it is determined the location must remain on for non-drinking purposes. In these cases, a "DO NOT DRINK – SAFE FOR HANDWASHING ONLY" sign will be posted.

Results of our Testing

Following instructions given in technical guidance developed by the New Jersey Department of Environmental Protection, we completed a plumbing profile for each of the buildings within Princeton School District. Through this effort, we identified and tested all drinking water and food preparation outlets. Of the 19 samples taken, all but 1 tested below the lead action level established by the US Environmental Protection Agency for lead in drinking water (15 μ g/l [ppb]).

The table below identifies the drinking water outlets that tested above the 15 μ g/l for lead, the actual lead level, and what temporary remedial action Princeton School District has taken to reduce the levels of lead at these locations.

Sample Location	First Draw Result in µg/l (ppb)	Remedial Action
EA-CF-1FL-STORE (water line	48.9	Disabled water line to the coffee
that feeds the coffee pot in the		pot pending flush sampling and
store)		remedial action.

Health Effects of Lead

High levels of lead in drinking water can cause health problems. Lead is most dangerous for pregnant women, infants, and children under 6 years of age. It can cause damage to the brain and kidneys, and can interfere with the production of red blood cells that carry oxygen to all parts of your body. Exposure to high levels of lead during pregnancy contributes to low birth weight and developmental delays in infants. In young children,

lead exposure can lower IQ levels, affect hearing, reduce attention span, and hurt school performance. At *very* high levels, lead can even cause brain damage. Adults with kidney problems and high blood pressure can be affected by low levels of lead more than healthy adults.

How Lead Enters our Water

Lead is unusual among drinking water contaminants in that it seldom occurs naturally in water supplies like groundwater, rivers and lakes. Lead enters drinking water primarily as a result of the corrosion, or wearing away, of materials containing lead in the water distribution system and in building plumbing. These materials include lead-based solder used to join copper pipe, brass, and chrome-plated brass faucets. In 1986, Congress banned the use of lead solder containing greater than 0.2% lead, and restricted the lead content of faucets, pipes and other plumbing materials. However, even the lead in plumbing materials meeting these new requirements is subject to corrosion. When water stands in lead pipes or plumbing systems containing lead for several hours or more, the lead may dissolve into the drinking water. This means the first water drawn from the tap in the morning *may* contain fairly high levels of lead.

Lead in Drinking Water

Lead in drinking water, although rarely the sole cause of lead poisoning can significantly increase a person's total lead exposure, particularly the exposure of children under the age of 6. EPA estimates that drinking water can make up 20% or more of a person's total exposure to lead.

For More Information

A copy of the test results is available in our central office for inspection by the public, including students, teachers, other school personnel, and parents, and can be viewed between the hours of 8:30 a.m. and 4:00 p.m. and are also available on our website at Eden Staff Matters. For more information about water quality in our school, contact Cindy Bott-Tomarchino Ed.D., BCBA-D, Director of Educational Services, 609-987-0099.

For more information on reducing lead exposure around your home and the health effects of lead, visit EPA's Web site at **www.epa.gov/lead**, call the National Lead Information Center at 800-424-LEAD, or contact your health care provider.

If you are concerned about lead exposure at this facility or in your home, you may want to ask your health care providers about testing children to determine levels of lead in their blood.

Sincerely,

Cindy Bott-Tomarchino Ed.D., BCBA-D Director of Educational Services The Eden School



Order ID: 7082843

Karl Environmental Group 20 Lauck Road Mohnton, PA 19540			Project: Eden	Austism					
Attn: Kelly Mays		Regul	atory ID:						
Sample Number: 7082843-01 Collector: KM		Site: EA-BLANK Collect Date: 08/10/2017	6:00 am	Sa Sa	mple II mple T	D: ype: S			
Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	Ву	Analysis Date	Ву
<u>Metals</u> Lead	< 1.00	μg/L	EPA 200.8	1.00	1	08/10/17	RPV	08/21/17 15:44	RPV
Sample Number: 7082843-02 Collector: KM		Site: EA-FP-1FL-CAFE Collect Date: 08/10/2017	6:02 am	Sa Sa	mple II mple T	D: ype: S			
Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	Ву	Analysis Date	Ву
Metals									
Lead	1.38	µg/L	EPA 200.8	1.00	1	08/10/17	RPV	08/21/17 15:46	RPV
Sample Number: 7082843-03 Collector: KM		Site: EA-TL-2FL-STAFF Collect Date: 08/10/2017	6:07 am	Sa Sa	mple II mple T	D: ype: S			
Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	Ву	Analysis Date	Ву
<u>Metals</u> Lead	1.15	µg/L	EPA 200.8	1.00	1	08/10/17	RPV	08/21/17 15:59	RPV
Sample Number: 7082843-04 Collector: KM		Site: EA-CF-2FL-STAFF Collect Date: 08/10/2017	6:06 am	Sa Sa	mple II mple T	D: ype: S			
Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	Ву	Analysis Date	Ву
<u>Metals</u> Lead	< 1.00	µg/L	EPA 200.8	1.00	1	08/10/17	RPV	08/18/17 22:17	RPV
Sample Number: 7082843-05 Collector: KM		Site: EA-WC-2FL-STAFF Collect Date: 08/10/2017	6:08 am	Sa Sa	mple II mple T): ype: S			
Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	Ву	Analysis Date	Ву
<u>Metals</u> Lead	< 1.00	µg/L	EPA 200.8	1.00	1	08/10/17	RPV	08/21/17 16:01	RPV

Report Generated On: 08/23/2017 8:58 am STL_Results Revision #1.6

7082843 Effective: 07/09/2014



1037F MacArthur Road, Reading, PA 19605 Phone: 800-433-6595

SUBURBAN TESTING LABS Fax: 610-375-4090 suburbantestinglabs.com

Page 1 of 7



Sample Number: 7082843-06 Collector: KM		Site: EA-WC-1FL-HALL Collect Date: 08/10/201	.EXER 17 6:10 am	Sa Sa	ample II ample T	D: īype: S			
Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	Ву	Analysis Date	Ву
<u>Metals</u> Lead	< 1.00	µg/L	EPA 200.8	1.00	1	08/10/17	RPV	08/21/17 16:03	RPV
Sample Number: 7082843-07 Collector: KM		Site: EA-WC-2FL-HALL Collect Date: 08/10/201	.209-2 17 6:13 am	Sa Sa	ample II ample T	D: īype: S			
Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	Ву	Analysis Date	Ву
<u>Metals</u> Lead	< 1.00	µg/L	EPA 200.8	1.00	1	08/10/17	RPV	08/21/17 16:05	RPV
Sample Number: 7082843-08 Collector: KM		Site: EA-WC-2FL-HALL Collect Date: 08/10/201	.209-1 17 6:14 am	Sa Sa	ample II ample T	D: īype: S			
Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	Ву	Analysis Date	Ву
<u>Metals</u> Lead	< 1.00	µg/L	EPA 200.8	1.00	1	08/10/17	RPV	08/21/17 16:07	RPV
Sample Number: 7082843-09 Collector: KM		Site: EA-CF-1FL-STOR Collect Date: 08/10/201	Sa Sa	ample II ample T	D: īype: S				
Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	Ву	Analysis Date	Ву
<u>Metals</u> Lead	48.9	μg/L	EPA 200.8	1.00	1	08/10/17	RPV	08/21/17 16:09	RPV
Sample Number: 7082843-10 Collector: KM		Site: EA-WC-1FL-HALL Collect Date: 08/10/201	.REC-1 17 6:22 am	Sa Sa	ample II ample T	D: īype: S			
Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	Ву	Analysis Date	Ву
<u>Metals</u> Lead	< 1.00	µg/L	EPA 200.8	1.00	1	08/10/17	RPV	08/21/17 16:11	RPV
Sample Number: 7082843-11 Collector: KM		Site: EA-WC-1FL-HALL Collect Date: 08/10/201	.REC-2 17 6:23 am	Sa Sa	ample II ample T	D: īype: S			
Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	Ву	Analysis Date	Ву
<u>Metals</u> Lead	< 1.00	µg/L	EPA 200.8	1.00	1	08/10/17	RPV	08/21/17 16:13	RPV
Sample Number: 7082843-12 Collector: KM		Site: EA-NS-1FL-NURS Collect Date: 08/10/201	iE 17 6:25 am	Sa Sa	ample II ample T	D: īype: S			
Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	Ву	Analysis Date	Ву
<u>Metals</u> Lead	1.16	µg/L	EPA 200.8	1.00	1	08/10/17	RPV	08/21/17 16:21	RPV
	Report Generated O S	n: 08/23/2017 8:58 am TL_Results Revision #1.6	7082843 Effective: 07/09/	/2014					

1037F MacArthur Road, Reading, PA 19605 Phone: 800-433-6595

SUBURBAN TESTING LABS Fax: 610-375-4090 suburbantestinglabs.com



Page 2 of 7



Sample Number: 7082843-13 Collector: KM		Site: EA-FP-1FL-146 Collect Date: 08/10/20	17 6:28 am	Sa Sa	ample II ample T	D: īype: S			
Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	Ву	Analysis Date	Ву
<u>Metals</u> Lead	< 1.00	µg/L	EPA 200.8	1.00	1	08/10/17	RPV	08/21/17 16:23	RPV
Sample Number: 7082843-14 Collector: KM		Site: EA-DW-1FL-143 Collect Date: 08/10/20	17 6:30 am	Sa Sa	ample II ample T	D: īype: S			
Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	Ву	Analysis Date	Ву
<u>Metals</u> Lead	< 1.00	µg/L	EPA 200.8	1.00	1	08/10/17	RPV	08/21/17 16:25	RPV
Sample Number: 7082843-15 Collector: KM		Site: EA-FP-1FL-143 Collect Date: 08/10/20	17 6:31 am	Sa Sa	ample II ample T	D: īype: S			
Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	Ву	Analysis Date	Ву
<u>Metals</u> Lead	< 1.00	µg/L	EPA 200.8	1.00	1	08/10/17	RPV	08/21/17 16:27	RPV
Sample Number: 7082843-16 Collector: KM		Site: EA-FP-1FL-149 Collect Date: 08/10/20	17 6:34 am	Sa Sa	ample II ample T	D: īype: S			
Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	Ву	Analysis Date	Ву
<u>Metals</u> Lead	< 1.00	µg/L	EPA 200.8	1.00	1	08/10/17	RPV	08/21/17 16:29	RPV
Sample Number: 7082843-17 Collector: KM		Site: EA-FP-2FL-251 Collect Date: 08/10/20	17 6:37 am	Sa Sa	ample II ample T	D: īype: S			
Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	Ву	Analysis Date	Ву
<u>Metals</u> Lead	< 1.00	µg/L	EPA 200.8	1.00	1	08/10/17	RPV	08/21/17 16:31	RPV
Sample Number: 7082843-18 Collector: KM		Site: EA-DW-2FL-HALI Collect Date: 08/10/20	_246-2 17 6:40 am	Sa Sa	ample II ample T	D: īype: S			
Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	Ву	Analysis Date	Ву
<u>Metals</u> Lead	< 1.00	µg/L	EPA 200.8	1.00	1	08/10/17	RPV	08/21/17 16:33	RPV
Sample Number: 7082843-19 Collector: KM		Site: EA-DW-2FL-HALI Collect Date: 08/10/20	_246-1 17 6:41 am	Sa Sa	ample II ample T	D: īype: S			
Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	Ву	Analysis Date	Ву
<u>Metals</u> Lead	< 1.00	µg/L	EPA 200.8	1.00	1	08/10/17	RPV	08/21/17 16:35	RPV
	Report Generated C	n: 08/23/2017 8:58 am TL_Results Revision #1.6	7082843 Effective: 07/09	9/2014					



SUBURBAN TESTING LABS Fax: 610-375-4090 suburbantestinglabs.com



Page 3 of 7



Sample Number: 7082843-20 Collector: KM		Site: EA-FP-2FL-241 Collect Date: 08/10/2017	6:43 am	Sa Sa	ample II ample T): ype: S			
Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	Ву	Analysis Date	Ву
Metals									
Lead	< 1.00	μg/L	EPA 200.8	1.00	1	08/10/17	RPV	08/21/17 16:37	RPV
Sample Number: 7082843-21 Collector:		Site: Laboratory Control S Collect Date: 08/10/2017	ample 6:43 am	Sa Sa	ample II ample T): ype:			
Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	Ву	Analysis Date	Ву
Metals									
Lead	14.3	μg/L	EPA 200.8	1.00	1	08/10/17	RPV	08/21/17 16:39	RPV
Sample Number: 7082843-22 Collector:		Site: Laboratory Control S Collect Date: 08/10/2017	ample Duplicate 6:43 am	Sa Sa	ample II ample T): ype:			
Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	Ву	Analysis Date	Ву
<u>Metals</u> Lead	14.2	µg/L	EPA 200.8	1.00	1	08/10/17	RPV	08/21/17 16:45	RPV

Sample Receipt Conditions:

All samples met the sample receipt requirements for the relevant analyses.

All results meet the requirements of STL's TNI (NELAC) Accredited Quality System unless otherwise noted. If your results contain any data qualifiers or comments, you should evaluate useability relative to your needs.

If collectors initials include "STL", samples have been collected in accordance with STL SOP SL0015.

All results reported on an As Received (Wet Weight) basis unless otherwise noted.

This laboratory report may not be reproduced, except in full, without the written approval of STL.

Results are considered Preliminary unless report is signed by authorized representative of STL.

Reviewed and Released By:

Alana Kopicz Project Manager

Alara M. Kopicz

7082843 Effective: 07/09/2014

SUBURBAN TESTING LABS



1037F MacArthur Road, Reading, PA 19605 Phone: 800-433-6595

Page 4 of 7





Alana Kopicz

TAT(Check One): Standard 24hr 48hr 72hr Other (Additional charges may apply for rush TAT. If not specified, standard TAT will apply)

Order ID:

Client Name:	Karl	Environmental	Group
--------------	------	---------------	-------

20 Lauck Road Address:

Mohnton, PA 19540

Phone: 610-856-7700 Fax: 610-856-5040

Email: kmays@karlenv.com

Address: Eden Autism

Payment / P.O. Info: 17-0695

Name: Eden Autism Lead in Water

2 Merwick Road, Princeton, NJ 08540

Contact Name: Kelly Mays

Comments:

NJ DOE Lead in Drinking Water Samples - First Draw

			-		T	5	S	ee Cod	es Belo	W	1
nple		mpler	mple	ø		lantit			be	tive	
SWTL Sar Number	Sample Description / Site ID:	Date Sa	Time Sa	Sampler Initials	Test(s) Requested:	Bottle Q	Matrix	Sample Type	Bottle Ty	Preserve	Comments / Field Data:
	EA-BLANK	8/10/2017	0600	KM	Lead	1	PW	G	Ρ	Н	Blank pHC2
	EA-FP-1FL-KITCH-3	8/10/2017		KM	Lead KM	1	PW	G	Ρ	Н	
	EA-FP-1FL-KITCH-2	8/10/2017		KM	Lead KIM	1	PW	G	Ρ	Н	
	EA-EP-1FL-KITCH-1	-8/10/2017-		KM	Lead	1	PW	G	Ρ	Н	
	EA-FP-1FL-CAFÉ	8/10/2017	0602	KM	Lead	1	PW	G	Ρ	Н	
	EA-TL-2FL-STAFF	8/10/2017	0607	KM	Lead	1	PW	G	Р	Н	
	EA-CF-2FL-STAFF	8/10/2017	0005	KM	Lead	1	PW	G	Р	Н	
	EA-WC-2FL-STAFF	8/10/2017	8008	KM	Lead	1	PW	G	Ρ	Н	
										V	211 (155 9-11-1-

Relinquished By:	Date:	Τ	Sample Conditions	Matr	ix Kev	Bottle Type Key	Reporting Options
Kelly Mays	Time: 1238	-	Submitted with COC?	NPW = Non-Potable Wa Solid = Raw Sludge, Dev	ter watered sludge, soil, etc.	P = Plastic G = Glass	SDWA Reporting
Received By: Kelly Baily 20	Date: 8/10/17 Time: 12:39	Temp °C: <u>15-3</u> Acceptable (V) N 02	Number of containers match number on COC	(reported as mg/l PW = Potable Water (no SDWA = Safe Drinking //	<g) t for SDWA compliance) Vater Act Potable Sample</g) 	O = Other Preservative Key	PWSID:
Refinquished By: Keely Agiler 20	Date: 8/10/11	Temp °C:	All containers in tact?	Sample Type Key	SDWA Sample Types	N = Sodium Thiosulfate A = Ascorbic Acid H = HNO ₃	Cther
Received in Leb/By:	Date 8-10-17	Acceptable Y JN Temp °C:	times	8HC = 8 Hr. Composite	E=Entry Point R=Raw C=Check S=Special	C = HCI $S = H_2SO_4$ OH = NaOH O = Other	Return a copy of this form with Report
L PINAR	Time: 7:41	Acceptable Y N	40 mL VOA vials free of headspace? Y / N	24HC = 24 Hr. Composite	M=Maximum Residence	NA = None Required	

Signing this form indicates your agreement with SWTL's Standard Terms and Conditions unless otherwise specified in writing. SLF059 Rev. 1.4 Effective November 12, 2014 Shaded areas are for SWTL use only.





Alana Kopicz

TAT(Check One): X Standard 24hr 48hr 72hr Other (Additional charges may apply for rush TAT. If not specified, standard TAT will apply)

Order ID:

Client Name:	Karl	Environmental	Group
	and the second se		

Address: 20 Lauck Road

Mohnton, PA 19540

Phone: 610-856-7700 Fax: 610-856-5040

Email: kmays@karlenv.com

Address: Eden Autism

Payment / P.O. Info: 17-0695

Name: Eden Autism Lead in Water

2 Merwick Road, Princeton, NJ 08540

Contact Name: Kelly Mays Comments:

NJ DOE Lead in Drinking Water Samples - First Draw

		pe	pe			~	5	See Cod	es Belo	w		
ample		ample	ample	e		uantit			be	tive		Marine
SWTL S Number	Sample Description / Site ID:	Date S	Time S	Sample Initials	Test(s) Requested:	Bottle Q	Matrix	Sample Type	Bottle Ty	Preserva	Comments	/ Field
	EA-WC-1FL-HALLEXER	8/10/2017	0610	KM	Lead	1	PW	G	Ρ	Н	iott ZI	
	EA-WC-2FL-HALL209-2	8/10/2017	0013	KM	Lead	1	PW	G	Р	H	¢1)	
	EA-WC-2FL-HALL209-1	8/10/2017	0014	KM	Lead	1	PW	G	P	Н		
	EA-CF-1FL-STORE	8/10/2017	0620	KM	Lead	1	PW	G	P	H		
	EA-WC-1FL-HALLREC-1	8/10/2017	0622	KM	Lead	1	PW	G	Р	H		
	EA-WC-1FL-HALLREC-2	8/10/2017	0.023	KM	Lead	1	PW	G	P	Н		
	EA-NS-1FL-NURSE	8/10/2017	NADS	KM	Lead	1	PW	G	P	н		
	EA-FP-1FL-146	8/10/2017	0628	KM	Lead	1	PW	G	P	H	\rightarrow	<u>۸</u>

Relinquished By:	Date: C-16-17	[Sample Conditions	Matrix Kev	Pottle Type Koy	PHKAPHLISE
Kelly & May Received By: Kelly Barley 20 Relinquished By: Kelly Laulee, 20	$\begin{array}{c c} & & & & & \\ \hline & & & & \\ \hline & & & & \\ \hline & & & &$	Temp °C: <u>15</u> . 3 Acceptable: €) N 1(2) Temp °C: <u>15</u> .3	Submitted with COC? (Y) N Number of containers match number on COC? (Y)/ N All containers in tact? (Y)/ N	NPW = Non-Potable Water Solid = Raw Sludge, Dewatered sludge, soli, etc. (reported as mg/kg) PW = Potable Water (not for SDWA compliance) SDWA = Safe Drinking Water Act Potable Sample Sample Type Key SDWA Sample Types	P = Plastic G = Glass O = Other Preservative Key N = Sodium Thiosulfate	
	Time: 12:41 Date: 8-10-17 Time: 2:45	Acceptable Acceptable Acceptable Acceptable Acceptable N	Tests within holding times (y) N 40 mL VOA vials free of headspace? Y / N	G = Grab D=Distribution BHC = 8 Hr. E=Entry Point Composite C=Check 24HC = 24 Hr. M=Maximum Composite Residence	$ \begin{array}{l} H = HNO_3 \\ C = HCI \\ S = H_2SO_4 \\ OH = NaOH \\ O = Other \\ NA = None \\ Required \end{array} $	Return a copy of this form with Report

Signing this form indicates your agreement with SWTL's Standard Terms and Conditions unless otherwise specified in writing. SLF059 Rev. 1.4 Effective November 12, 2014 Shaded areas are for SWTL use only.





7082843 Alana Kopicz

TAT(Check One): 🔀 Standard 🗖 24hr 🗍 48hr 🗍 72hr 🗍 Other	
(Additional charges may apply for rush TAT, If not specified, standard TAT will apply	2

Order ID:

Client Name:	Karl	Environmental	Group
Onent Name.			

Address: 20 Lauck Road

Mohnton, PA 19540

______{Phone:} <u>610-856-7700</u> _{Fax:} 610-856-5040 Address: Eden Autism

Froject Name: Eden Autism Lead in Water

2 Merwick Road, Princeton, NJ 08540

Contact Name: Kelly Mays

Email: kmays@karlenv.com Payment / P.O. Info: 17-0695

Comments:

NJ DOE Lead in Drinking Water Samples - First Draw

		þ	p			~	See Codes Below					
ample		ample	ample	<u>8</u>		uantit			be	tive		, management of the state of th
SWTL S Number	Sample Description / Site ID:	Date S	Time S	Sample Initials	Test(s) Requested:	Bottle Q	Matrix	Sample Type	Bottle Ty	Preserva	Comme	nts / Field
	EA-DW-1FL-143	8/10/2017	0630	KM	Lead	1	PW	G	Р	Н	DHK-	 2
	EA-FP-1FL-143	8/10/2017	063	KM	Lead	1	PW	G	Ρ	Н	K))	
	EA-FP-1FL-149	8/10/2017	(2034	KM	Lead	1	PW	G	Р	Н		
ð	EA-FP-2FL-251	8/10/2017	0637	KM	Lead	1	PW	G	P	H		
	EA-DW-2FL-HALL246-2	8/10/2017	0040	KM	Lead	1	PW	G	Р	Н		
	EA-DW-2FL-HALL246-1	8/10/2017	(score)	KM	Lead	1	PW	G	P	Н	 -	
	EA-FP-2FL-241	8/10/2017	OGYP	KM	Lead	1	PW	G	P	H		
			- • 13			-	-	-	•		H. 1.)s	L SESCION

Relinquished By:	Date: 8-16-17		Sample Conditions	Mati	rix Key	Bottle Type Key	Reporting Options
Kellyzmaen	Time: 12.75	-	Submitted with COC?	NPW = Non-Potable Water Solid = Raw Sludge, Dewatered sludge, soli, etc. (reported as mg/kg) PW = Potable Water (not for SDWA compliance) SDWA = Safe Drinking Water Act Potable Someter		P = Plastic	SDWA Reporting
Received By:	Date: 8/10/17	Temp %: 15.3	Number of containers			0 = Other	PWSID:
feely Javen 20	Time: 12:39	Acceptable (Y)N	match number on COC? (Y)/ N			Preservative Key	Fax
Relinquished By:	Date: 8/10/17	Temp °C: /5.3	All containers in tact? Q_{1} N	Sample Type Key	SDWA Sample Types	N = Sodium Thiosulfate	
feely Buildy to	Time: $12:41$	Acceptable: Y/N	Tests within holding	G = Grab	D=Distribution E≈Entry Point	H = HNO ₃ C = HCI	Return a copy of this form with
Received in Lab By:	Date: 8-10-17	Temp °C:	umes VV N	8HC = 8 Hr. Composite	R=Raw C=Check	S = H ₂ SO ₄ OH = NaOH	Report
L'Ali Onde	Time: 12:41	Acceptable: Y / N	40 mL VOA vials free of headspace? Y / N	24HC = 24 Hr. Composite	S=Special M=Maximum Residence	O = Other NA = None Required	

Signing this form indicates your agreement with SWTL's Standard Terms and Conditions unless otherwise specified in writing. SLF059 Rev. 1.4 Effective November 12, 2014 Shaded areas are for SWTL use only.